

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES**

Memo No : IND/WB/FES/20182019/42891

DATE: 24/01/2019

From :

The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.


To :

D.A.V. PUBLIC SCHOOL
G+2 Storied Educational Building in favour of D.A.V. PUBLIC SCHOOL, over J.L.No.19,
Plot No.335,340,341,
Mouza:Nabaghanapur,Dist Paschim
Bardhaman
Durgapur F.S., Durgapur PS,
Paschim Bardhaman - 713385 .


Sub :Fire Safety Certificate for the occupancy of an existing construction of G + 2
storied building under group Educational at the premises no. D.A.V. PUBLIC
SCHOOL,over J.L.No.19,
Plot No.335,340,341,
Mouza:Nabaghanapur,Dist Paschim
Bardhaman, Durgapur PS, Paschim Bardhaman - 713385

This is in reference to your Application No. IND/WB/FES/20182019/42891,dated 24/01/2019,
regarding the Fire Safety Certificate for the occupancy of an existing construction of G + 2
storied building under group Educational at the premises no. D.A.V. PUBLIC SCHOOL,over
J.L.No.19,
Plot No.335,340,341,
Mouza:Nabaghanapur,Dist Paschim
Bardhaman, Durgapur PS, Paschim Bardhaman - 713385.

The performance of the Fire Fighting System as incorporated in the buildings were tested at
random and found satisfactorily working condition. In view of the above this office is releasing
the Fire Safety Certificate for occupancy of the aforesaid building.



Head Master
D.A.V Public School
Jhanjra Area



Manager
D.A.V. PUBLIC SCHOOL
JHANJRA (W.B.)

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
2. The interior finish decoration of building made with low flame spread material confirming I.S specification.
3. To eliminate risk of fire hazards , good house keeping both for insides and outside of building shall be strictly maintained.
4. Existing electrical wiring of the whole building shall have to be carefully checked for any where and tear in them, particularly lines above false ceiling & ducts.
5. The fire check door shall be sealed with rubber sealing properly in order to prevent the percolation of smoke.
6. A fire control room including a close circuit T.V system preferably will have to be installed which will observe the building
7. The notice of Fire Fighting and evacuation from the building shall be prepared and displayed at all venerable places of the building.
8. Floor numbers and directional sign of escape route shall be displayed prominently.
9. Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
10. First AID Fire Fighting system shall be provided as per I.S Specification .
11. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
12. Fire License shall have to be obtained for storing and processing with L.P.G and other combustibile articles.
13. All the employees including the managerial staff shall have adequate knowledge of using fire extinguisher and action to be taken for evaquation of building in case of emergency.
14. Each year a certificate is to be obtained from West Bengal Fire & Emergency Services, certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements and installation of the building



Head Master
D.A.V Public School
Jhanjra Area



Manager
D.A.V. PUBLIC SCHOOL
JHANJRA (W.B.)

GOVERNMENT OF WEST BENGAL
OF THE DIVISIONAL FIRE OFFICER
Jhankar Road, Kolkata - 700016

Divisional Fire Officer
West Bengal Fire & Emergency Services

Signature valid
Digitally signed by ASHIM
SARKAR
Date: 2019.01.24 13:50:17 IST

Ratna...
Head Master
D.A.V Public School
Jhanjra Area

...
Manager
D.A.V. PUBLIC SCHOOL
JHANJRA (W.B.)