

Government Of West Bengal Office Of The Divisional Fire Officer, Paschim Bardhaman West Bengal Fire & Emergency Services Bhangakhuti, Purba Burdwan, P.O.:- Rajbati, Pin :- 713104

Memo no.: IND/WB/FES/20182019/42891

Date: 18-08-2021

From:

Divisional Fire Officer, Paschim Bardhaman West Bengal Fire & Emergency Services

To: D.A.V. Public School.

Mouza - Nabaghanapur, ECL Jhanjra area, Plot no. 338, 340, 341, J.L no. 19, under Laudoha G.P, P.S Laudoha, Dist. Paschim Bardhaman, Pin - 713385.

Sub: Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational occupancy, in favour of "D.A.V. Public School" at, Mouza - Nabaghanapur, ECL Jhanjra area, Plot no. 338, 340, 341, J.L no. 19, under Laudoha G.P, P.S Laudoha, Dist. Paschim Bardhaman, Pin - 713385.

This is in reference to your application no. 0125191219100045 dated 14-08-2021 regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational occupancy, in favour of "D.A.V. Public School" at, Mouza - Nabaghanapur, ECL Jhanjra area, Plot no. 338, 340, 341, J.L no. 19, under Laudoha G.P, P.S Laudoha, Dist. Paschim Bardhaman, Pin - 713385.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- 1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way. Basement shall not be used other than Car parking.
- 2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
- 3.To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
- 4. Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them,

The authenticity of this document can be verified by accessing the URL: edistricts bigov. In and then clicking on the "Verification of Digitally Signed Document" link and keying in the Unique Number: 0125191219100045.

D.A.V Public School

D.A.V. PUBLIC SCHOOpwered By emsigner Please visit www.emsigner.com

For secure paperless solutions

JHANJRA (W.B.)

particularly lines above false celling and ducts.

- 5.The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
- 6.Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
- 7.Transformer and switchgear room shall be protected with automatic co2 or DCP fire extinguisher conforming I.S specification.
- 8. First aid firefighting system shall be provided as per I.S specification.
- 9.Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
- 10. Fire License shall have to be obtained for storing and processing with highly combustible articles.
- 11. The Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

Signature valid
Digitally signed P. PULACK
SHARMA
Date: 2021.08 / 8 14:46:55 IST

Divisional Fire Officer, Paschim Bardhaman West Bengal Fire & Emergency Services

Head Master

D.A.V. Public School

Jhanjra Area

Manager
D.A.V. PUBLIC SCHOOL
JHANJRA (W.B.)