



सत्यमेव जयते

Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Paschim Bardhaman Division, 1st Floor, Durgapur Fire Station Building, City Centre, Durgapur-16

Memo No.: FSR/IND/WB/FES/20182019/42891

Date : 25-10-2024

From :
Divisional Fire Officer
Paschim Bardhaman Division,
West Bengal Fire & Emergency Services

To :
D.A.V. Public School, ECL, Jhanjra.
Mouza Nabaghanapur, ECL Jhanjra area, Plot no. 338, 340, 341, J.L no. 19, under Loudoha G.P, P.S Loudoha, Dist.
Paschim Bardhaman, Pin - 713385

Sub : Renewal of Fire Safety Certificate for the Existing G+2 storied educational building in favour of D.A.V. Public School, at, Mouza - Nabaghanapur, ECL Jhanjra area, Plot no. 338, 340, 341, J.L no. 19, under Loudoha G.P, P.S Loudoha, Dist. Paschim Bardhaman, Pin - 713385.

This is in reference to your AIN 211912406300002543 dated 22-Oct-2024 regarding Renewal of Fire Safety Certificate for the Existing G+2 storied educational building in favour of D.A.V. Public School, at, Mouza - Nabaghanapur, ECL Jhanjra area, Plot no. 338, 340, 341, J.L no. 19, under Loudoha G.P, P.S Loudoha, Dist. Paschim Bardhaman, Pin - 713385..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

1. Entry / Exit and Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The Interior finish decoration of buildings shall be made with low flame spread material confirming to



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300002543

the relevant I.S. Specification.

3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the buildings shall be strictly maintained.
4. Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
5. All the vertical and horizontal ducts to be sealed by approved fire resisting materials.
6. Floor numbers and directional sign of escape route shall be displayed prominently
7. A closed circuit TV system will have to be maintained which will observe all the floors of the buildings.
8. The notice of Fire Fighting, Exit Signage and Evacuation Plan from the building shall be prepared and displayed at all vulnerable places of the buildings.
9. The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
10. Mock Fire Practice and evacuation drill shall be performed periodically with participation of all the occupants and employees of the buildings.
11. A crew of trained Fireman under an experienced officer shall be maintained round the clock for safety of the buildings.
12. Transformer, Switch Gear room, Electrical Panel Room and Electrical Main & Meter Room shall be protected with automatic Fire detection and suppression system conforming relevant I.S. Specification.
13. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
14. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the buildings to keep them in perfectly good working condition at all the times.
15. If required, the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
16. Periodical flashing of water from water-based suppression system shall be made to maintain the efficient working performance of above mentioned system.
17. The Fire Safety and electrical audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
18. Fire License have to be obtained for storing and processing with L.P.G or other inflammable article.
19. This Renewal of Fire Safety Certificate is valid for 03 (Three) years from the date of issue of this letter and has to be renewed within validity limit.

Valid Upto : 24-Oct-2027

Memo No.:

FSR/IND/WB/FES/20182019/42891



Signature valid

Digitally Signed.
Name: RATAN KUMAR HALDER
Date: 25-Oct-2022 17:47:06
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300002543